



**DATA SHEET 08 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3006**

Manufacturer: Bauer Gear Motor GmbH  
Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXE11LA42-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power :	3.0 / 4.0					kW
Voltage:	110	230	400	500	690	V
Current:	23.5 / 30	11.3 / 14.4	6.5 / 8.3	5.2 / 6.6	3.75 / 4.8	A
Power factor:	0.85 / 0.94					
Frequency:	50					Hz
Speed: (motor)	1430 / 2875					min <sup>-1</sup>
Duty Type:	S1					
I <sub>A</sub> /I <sub>N</sub> ratio:	6.2 / 7.0					
Thermal classification:	155 (F)					

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	
Time t <sub>E</sub> :	13 / 8	13 / 8	13 / 8	s

Test report PTB Ex 01-30089

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
On behalf of PTB:

Braunschweig, May 4, 2023

Dr.-Ing. C. Lehm



**DATA SHEET 09 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3006**

Manufacturer: Bauer Gear Motor GmbH  
 Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXE11LC84-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power :	1.1 / 2.2					kW
Voltage:	110	230	400	500	690	V
Current:	14.7 / 18.2	7.0 / 8.7	4.05 / 5.0	3.25 / 4.0	2.35 / 2.9	A
Power factor:	0.58 / 0.85					
Frequency:	50					Hz
Speed: (motor)	712 / 1435					min <sup>-1</sup>
Duty Type:	S1					
I <sub>A</sub> /I <sub>N</sub> ratio:	3.9 / 5.6					
Thermal classification:	155 (F)					

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	
Time t <sub>E</sub> :	30 / 11	30 / 11	30 / 11	s

Test report PTB Ex 01-30089

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
 On behalf of PTB:

Braunschweig, May 4, 2023

Dr.-Ing. C. Lehmann



**DATA SHEET 01 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3003**

Manufacturer: Bauer Gear Motor GmbH  
Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE06LA4-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:			0.12			kW
Voltage:	110	220	400	500		V
Current:	1.51	0.75	0.42	0.33		A
Power factor:			0.73			
Frequency:			50			Hz
Speed: (motor)			1355			min <sup>-1</sup>
Duty Type:			S1			
I <sub>A</sub> /I <sub>N</sub> ratio:			3.4			
Thermal classification:			155 (F)			

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	T4	
Time t <sub>E</sub> :	160	160	160	40	s

Test report PTB Ex 99-30031

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
On behalf of PTB:

Braunschweig, May 4, 2023

*U. Lehmann*  
Dr.-Ing. C. Lehmann









**DATA SHEET 09 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3003**

Manufacturer: Bauer Gear Motor GmbH  
 Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE06LA4-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:		0.12				kW
Voltage:	110	220	440	500		V
Current:	1.51	0.75	0.37	0.33		A
Power factor:		0.73				
Frequency:		60				Hz
Speed: (motor)		1655				min <sup>-1</sup>
Duty Type:		S1				
I <sub>A</sub> /I <sub>N</sub> ratio:		3.9				
Thermal classification:		155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	T4	
Time t <sub>E</sub> :	160	160	160	40	s

Test report PTB Ex 00-30031

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
 On behalf of PTB:

Braunschweig, July 10, 2023

*C. Lehmann*  
 Dr.-Ing. C. Lehmann















**DATA SHEET 11 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3005**

Manufacturer: Bauer Gear Motor GmbH  
 Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE09LA4-...

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:			1.1				kW
Voltage:	110	220	440	500	690		V
Current:	8.9	4.45	2.2	1.96	1.42		A
Power factor:			0.8				
Frequency:			60				Hz
Speed: (motor)			1724				min <sup>-1</sup>
Duty Type:			S1				
I <sub>A</sub> /I <sub>N</sub> ratio:			7.0				
Thermal classification:			155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	T4	
Time t <sub>E</sub> :	40	40	40	14	s

Test report PTB Ex 23-32094

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
 On behalf of PTB:

Braunschweig, June 21, 2023

*M. Thepans*  
 Dr.-Ing. M. Thepans  
 Direktor und Professor

ZSEx10102e c

**DATA SHEET 13 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3005**

Manufacturer: Bauer Gear Motor GmbH  
Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE09XA4-...

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:			1.5				kW
Voltage:	110	220	440	500	690		V
Current:	12	6,0	3.0	2.6	1.91		A
Power factor:			0.79				
Frequency:			60				Hz
Speed: (motor)			1723				min <sup>-1</sup>
Duty Type:			S1				
I <sub>A</sub> /I <sub>N</sub> ratio:			7.3				
Thermal classification:			155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	T4	
Time t <sub>E</sub> :	29	29	28	7	s

Test report PTB Ex 23-32094

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
On behalf of PTB:

Braunschweig, June 21, 2023

*M. Theßen*  
Dr.-Ing. M. Theßen  
Direktor und Professor



**DATA SHEET 05 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3006**

Manufacturer: Bauer Gear Motor GmbH  
 Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE11LA4-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power :			4.0				kW
Voltage:	110	230	400	500	690		V
Current:	31.5	15.0	8.7	6.9	5.1		A
Power factor:			0.81				
Frequency:			50				Hz
Speed: (motor)			1445				min <sup>-1</sup>
Duty Type:			S1				
I <sub>A</sub> /I <sub>N</sub> ratio:			7.8				
Thermal classification:			155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	
Time t <sub>E</sub> :	9	9	9	s

Test report PTB Ex 99-30036

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
 On behalf of PTB:

Braunschweig, May 4, 2023

*U. Lehmann*  
 Dr.-Ing. C. Lehmann



ZSEx10102e c



**DATA SHEET 14 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3006**

Manufacturer: Bauer Gear Motor GmbH  
 Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE11LA4-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power :			4.0				kW
Voltage:	110	220	440	500	690		V
Current:	31.5	15.8	7.9	6.9	5.1		A
Power factor:			0.81				
Frequency:			60				Hz
Speed: (motor)			1745				min <sup>-1</sup>
Duty Type:			S1				
I <sub>A</sub> /I <sub>N</sub> ratio:			8.4				
Thermal classification:			155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	
Time t <sub>E</sub> :	9	9	9	s

Test report PTB Ex 00-30034

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
 On behalf of PTB:

Braunschweig, July 10, 2023

*U. Lehrmann*  
 Dr.-Ing. C. Lehrmann







**DATA SHEET 01 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3006**

Manufacturer: Bauer Gear Motor GmbH  
 Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE11SA4-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:			2.2				kW
Voltage:	110	230	400	500	690		V
Current:	18.5	8.9	5.1	4.1	2.95		A
Power factor:			0.82				
Frequency:			50				Hz
Speed: (motor)			1435				min <sup>-1</sup>
Duty Type:			S1				
I <sub>A</sub> /I <sub>N</sub> ratio:			6.2				
Thermal classification:			155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	
Time t <sub>E</sub> :	12	12	12	s

Test report PTB Ex 99-30037

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
 On behalf of PTB:

Braunschweig, May 4, 2023

*C. Lehmann*  
 Dr.-Ing. C. Lehmann







**DATA SHEET 01 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3007**

Manufacturer: Bauer Gear Motor GmbH  
 Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE13LA4-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:			5.5				kW
Voltage:	110	230	400	500	690		V
Current:	43	20.6	11.9	9.5	6.9		A
Power factor:			0.80				
Frequency:			50				Hz
Speed: (motor)			1460				min <sup>-1</sup>
Duty Type:			S1				
I <sub>A</sub> /I <sub>N</sub> ratio:			8.1				
Thermal classification:			155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	
Time t <sub>E</sub> :	13	13	12	s

Test report PTB Ex 99-30038

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
 On behalf of PTB:

Braunschweig, May 4, 2023

Dr.-Ing. C. Lehmann



**DATA SHEET 03 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3007**

Manufacturer: Bauer Gear Motor GmbH  
Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE13LA4-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:			5.5				kW
Voltage:	110	220	440	500	690		V
Current:	43	21.5	10.7	9.5	6.9		A
Power factor:			0.80				
Frequency:			60				Hz
Speed: (motor)			1760				min <sup>-1</sup>
Duty Type:			S1				
I <sub>A</sub> /I <sub>N</sub> ratio:			8.6				
Thermal classification:			155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring


For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	
Time t <sub>E</sub> :	13	13	12	s

Test report PTB Ex 00-30035

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
On behalf of PTB:

Braunschweig, July 10, 2023

  
Dr.-Ing. C. Lehrmann



## DATA SHEET 02 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3008

Manufacturer: Bauer Gear Motor GmbH  
Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE16LA4-\*\*\*

### Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:			9.5				kW
Voltage:	200	230	400	500	690		V
Current:	38	33	19.1	15.3	11.1		A
Power factor:			0.84				
Frequency:			50				Hz
Speed: (motor)			1472				min <sup>-1</sup>
Duty Type:			S1				
I <sub>A</sub> /I <sub>N</sub> ratio:			8.0				
Thermal classification:			155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to  $\pm 5\%$  and the mains frequency by up to  $\pm 2\%$  from the rated values, in keeping with range A according to IEC 60034-1.

### Temperature monitoring

For the selection of a current dependent time-lag protective device, the times  $t_E$  were determined as follows:

Temperature class:	T1	T2	T3	
Time $t_E$ :	14	14	9	s

Test report PTB Ex 99-30129

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
On behalf of PTB:

Braunschweig, May 4, 2023

Dr.-Ing. C. Lehm





**DATA SHEET 06 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3008**

Manufacturer: Bauer Gear Motor GmbH  
Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE16LA4-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:			9.5				kW
Voltage:	200	220	440	500	690		V
Current:	38	34.5	17.3	15.3	11.1		A
Power factor:			0.84				
Frequency:			60				Hz
Speed: (motor)			1772				min <sup>-1</sup>
Duty Type:			S1				
I <sub>A</sub> /I <sub>N</sub> ratio:			8.2				
Thermal classification:			155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	
Time t <sub>E</sub> :	14	14	9	s

Test report PTB Ex 00-30036

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
On behalf of PTB:

Braunschweig, July 10, 2023

  
Dr.-Ing. C. Lehmann



**DATA SHEET 07 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3008**

Manufacturer: Bauer Gear Motor GmbH  
Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE16LA4-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:			11				kW
Voltage:	200	220	440	500	690		V
Current:	45	41	20.5	18.0	13.0		A
Power factor:			0.83				
Frequency:			60				Hz
Speed: (motor)			1769				min <sup>-1</sup>
Duty Type:			S1				
I <sub>A</sub> /I <sub>N</sub> ratio:			8.2				
Thermal classification:			155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	
Time t <sub>E</sub> :	10	10	6	s

Test report PTB Ex 00-30036

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
On behalf of PTB:

Braunschweig, July 10, 2023

Dr.-Ing. C. Lehmann



**DATA SHEET 01 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3008**

Manufacturer: Bauer Gear Motor GmbH  
 Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE16MA4-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:			7.5				kW
Voltage:	190	230	400	500	690		V
Current:	32	26.5	15.2	12.2	8.8		A
Power factor:			0.84				
Frequency:			50				Hz
Speed: (motor)			1467				min <sup>-1</sup>
Duty Type:			S1				
I <sub>A</sub> /I <sub>N</sub> ratio:			6.9				
Thermal classification:			155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	
Time t <sub>E</sub> :	16	16	15	s

Test report PTB Ex 99-30129

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
 On behalf of PTB:

Braunschweig, May 4, 2023

*C. Lehmann*  
 Dr.-Ing. C. Lehmann





**DATA SHEET 05 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3008**

Manufacturer: Bauer Gear Motor GmbH  
 Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE16MA4-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:			7.5				kW
Voltage:	190	220	440	500	690		V
Current:	32	27.5	13.8	12.2	8.8		A
Power factor:			0.84				
Frequency:			60				Hz
Speed: (motor)			1767				min <sup>-1</sup>
Duty Type:			S1				
I <sub>A</sub> /I <sub>N</sub> ratio:			7.6				
Thermal classification:			155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	
Time t <sub>E</sub> :	16	16	15	s

Test report PTB Ex 00-30036

Konformitätsbewertungsstelle Sektor Explosionsschutz  
 On behalf of PTB:

Braunschweig, July 10, 2023

Dr.-Ing. C. Lehrmann



**DATA SHEET 04 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3008**

Manufacturer: Bauer Gear Motor GmbH  
 Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE16XA4-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:			11				kW
Voltage:	170	230	400	500	690		V
Current:	51	38	22	17.5	12.6		A
Power factor:			0.84				
Frequency:			50				Hz
Speed: (motor)			1473				min <sup>-1</sup>
Duty Type:			S1				
I <sub>A</sub> /I <sub>N</sub> ratio:			8.1				
Thermal classification:			155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	
Time t <sub>E</sub> :	12	12	10	s

Test report PTB Ex 99-30129

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
 On behalf of PTB:

Braunschweig, May 4, 2023

*C. Lehmann*  
 Dr.-Ing. C. Lehmann



**DATA SHEET 08 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3008**

Manufacturer: Bauer Gear Motor GmbH  
 Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEHE16XA4-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power:			11				kW
Voltage:	200	220	440	500	690		V
Current:	43.5	39.5	19.8	17.5	12.6		A
Power factor:			0.84				
Frequency:			60				Hz
Speed: (motor)			1773				min <sup>-1</sup>
Duty Type:			S1				
I <sub>A</sub> /I <sub>N</sub> ratio:			8.7				
Thermal classification:			155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	
Time t <sub>E</sub> :	12	12	10	s

Test report PTB Ex 00-30036

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
 On behalf of PTB:

Braunschweig, July 10, 2023

Dr.-Ing. C. Lehrmann













**DATA SHEET 07 TO EU-TYPE EXAMINATION CERTIFICATE PTB 23 ATEX 3006**

Manufacturer: Bauer Gear Motor GmbH  
 Eberhard-Bauer-Straße 37, 73734 Esslingen, Germany

for three phase motor type .../DXEU11LA4-\*\*\*

Ratings

This certificate is valid for the following designs providing the motors of this type differ only negligibly from the sample tested as regards the electrical and thermal stresses:

Power :			1.1				kW
Voltage:	110	230	400	500	690		V
Current:	8.7	4.2	2.4	1.92	1.39		A
Power factor:			0.88				
Frequency:			50				Hz
Speed: (motor)			1430				min <sup>-1</sup>
Duty Type:			S1				
I <sub>A</sub> /I <sub>N</sub> ratio:			6.1				
Thermal classification:			155 (F)				

In addition to the above-mentioned voltages, intermediate values are also permissible. The associated currents are to be converted in the inverse ratio to the voltages. The mains voltage may vary by up to ± 5% and the mains frequency by up to ± 2% from the rated values, in keeping with range A according to IEC 60034-1.

Temperature monitoring

For the selection of a current dependent time-lag protective device, the times t<sub>E</sub> were determined as follows:

Temperature class:	T1	T2	T3	T4	
Time t <sub>E</sub> :	40	40	40	12	s

Test report PTB Ex 99-30036

Konformitätsbewertungsstelle, Sektor Explosionsschutz  
 On behalf of PTB:

Braunschweig, May 4, 2023

Dr.-Ing. C. Lehmann

